CERTIFICATION FOR GAS TEST
Building Department - Inc. Village of Great Neck
61 Baker Hill Road, Great Neck, New York 11023

For Office Use Only

Gas Test No. 107

Check One Box
9 **Building** 9 **Plumbing**

Permit No.

MERCURY/AIR TEST **Date: 07/23/02**

Circle One of the Above

Location: 2 RUTH COURT, GREAT NECK, NY 11023

NEW YORK STATE UNIFORM FIRE PREVENTION AND BUILDING CODE
SUBCHAPTER G - REFERENCE STANDARDS - OSHA: Safety and Health

Regulations for Construction <RS -35-4> - Part 1910 - Occupational Safety and Health Standards - Subpart H - Hazardous Materials
1910.110 - Storage and handling of liquified petroleum gases - 1910.110(b) Basic rules - 1910.110(b)(8) Piping

1910.110(b)(8)(ix) All piping, tubing, or hose shall be tested after assembly and proved free from leaks at not less than normal operating pressures. After installation, piping and tubing of all domestic and commercial systems shall be tested and proved free of leaks using a manometer or equivalent device that will indicate a drop in pressure. Test shall not be made with a flame.

Witnessed by _____
Name **Title**

After all gas piping is fitted and fastened and all outlets capped up, there must be applied by the plumber, in the presence of the Building Inspector, a test with air to a pressure equal to a column of mercury six (6) inches in height, or a minimum of Five (5) psi, the same to stand for ten (10) minutes. Only an approved gauge shall be used..